Energy Conversion and Management 171 (2018) 339–349

Contents lists available at ScienceDirect

Energy Conversion and Management

journal homepage: www.elsevier.com/locate/enconman

Use of floating PV plants for coordinated operation with hydropower plants: Case study of the hydroelectric plants of the São Francisco River basin

Naidion Motta Silvério[a], Regina Mambeli Barros[b,*], Geraldo Lúcio Tiago Filho[b], Miguel Redón-Santafé[c], Ivan Felipe Silva dos Santos[a], Victor Eduardo de Mello Valério[a]

[a] Federal University of Itajubá, (Engenharia da Energia da Universidade Federal de Itajubá), Av. BPS, 1303, Itajubá, MG, Brazil
[b] Federal University of Itajubá, National Reference Center in Small Hydropower, (Instituto de Recursos Naturais da Universidade Federal de Itajubá, Centro Nacional de Referência em Pequenas Centrais Hidrelétricas), Av. BPS, 1303, Itajubá, MG, Brazil
[c] Universidad Politécnica de Valencia, Departamento de Ingeniería Rural y Agroalimentaria, Camino de Vera s/n, 46022 Valencia, Spain

ARTICLE INFO

Keywords:
Hydro/PV coordinated operation
Hybrid PV hydroelectric power plant
Floating PV power plant
Solar hydroelectric power plant

ABSTRACT

In recent years, the Brazilian electricity sector has seen a considerable reduction in hydroelectric production and an increase in dependence on the complementation of thermoelectric power plants to meet the energy demand. This issue has led to an increase in greenhouse gas emissions, which has intensified climate change and modified rainfall regimes in several regions of the country, as well as increased the cost of energy. The use of floating PV plants in coordinated operation with hydroelectric plants can establish a mutual compensation between these sources and replace a large portion of the energy that comes from thermal sources, thereby reducing the dependence on thermoelectric energy for hydropower complementation. Thus, this paper presents a procedure for technically and economically sizing floating PV plants for coordinated operation with hydroelectric plants. A case study focused on the hydroelectric plants of the São Francisco River basin, where there has been intense droughts and increased dependence on thermoelectric energy for hydropower complementation. The results of the optimized design show that a PV panel tilt of approximately 3° can generate energy at the lowest cost (from R $298.00/MWh to R$312.00/MWh, depending on the geographical location of the FLOATING PV platform on the reservoir). From an energy perspective, the average energy gain generated by the hydroelectric plant after adding the floating PV generation was 76%, whereas the capacity factor increased by 17.3% on average. In terms of equivalent inflow, the PV source has a seasonal profile that compliments the natural inflow of the river. Overall, the proposed coordinated operation could replace much of the thermoelectric generation in Brazil.

1. Introduction

In Brazil, approximately 91% of the power generation is from hydropower plants (64.3%) and thermal plants (26.6%) [1]. The predominance of these two sources is due to the mode of operation of the Brazilian power and electrical system. Specifically, hydropower plants (with low emissions and costs) operate as a generation base [2], and thermal plants (with high emissions and costs) operate in a complementary state, thereby providing energy during the dry period and meeting the peak demand [3]. However, since 2012, the Annual Energy Balance [1] has exhibited a notable reduction in the contribution of hydroelectric plants and a gradual increase in the contribution of thermal power plants to the total energy supply. According to [4], low hydroelectric production can be linked to the recent climatic changes that have affected rainfall regimes in several regions of the country, mainly in the northeast. Prado et al. [5] noted that this trend is part of a vicious cycle of increased emissions, accelerated climate change, reduced hydropower production, increased dependence on thermal plants, and higher energy costs.

Thus, there is an evident need to investigate low-cost and clean energy sources that are capable of reducing the dependence on thermoelectric plants and complimenting hydropower. Among them, the use of solar energy could provide an important alternative from both an environmental perspective, due to low emissions [6], and a cost reduction perspective associated with future technological advancements [7]. However, the replacement of thermal power generation will require the construction of large centralized photovoltaic (PV) plants in the power system. This process can have adverse effects due to the typical fluctuations in the power output of these sources [8]. According to An et al. [9], the coordinated operation of a PV power plant and a hydroelectric plant (connected to the electric system through the same substation) can stabilize the PV output power and allow the

* Corresponding author.
E-mail addresses: mambeli@unifei.edu.br (R.M. Barros), miresan@agf.upv.es (M. Redón-Santafé).

https://doi.org/10.1016/j.enconman.2018.05.095
Received 8 January 2018; Received in revised form 24 May 2018; Accepted 26 May 2018
Available online 02 June 2018
0196-8904/

introduction of the energy source at a large scale. Alternatively, the PV energy can supplement hydroelectric power generation in dry periods and can increase the ability to meet peak demands.

For hydro/PV coordinated operation to be possible, the PV power plant must be physically close to the hydropower plant so that both can be dispatched from the same substation [9] and that potential disturbances to frequency and speed regulators caused by the high variability in PV power generation in different geographical regions can be reduced [10]. This proximity requirement makes floating PV plants interesting options compared to land-based plants due to the possibility of occupying the large space that is available on the surface of the reservoir of the hydroelectric plant [11] rather than occupying surrounding areas that could be developed for other activities (recreation, tourism, etc.) [12] and that usually have unfavorable topography for the construction of large flat areas (on the order of km^2) with PV panels.

This paper presents a procedure for technically and economically sizing floating PV plants for coordinated operation with hydroelectric plants. To consider the various losses associated with large photovoltaic systems, calculations were performed with the help of PVSyst® software. The case study focused on hydroelectric plants in the São Francisco River basin, the second most important basin in the country. This basin is mainly located in a region that is extremely vulnerable to intense droughts and that has experienced a corresponding increase in the dependence on thermoelectric energy to compliment hydropower production [13].

The paper is organized as follows. Section 2 presents a summary of the main projects using floating PV technology to demonstrate the technological variations and results of each project. Section 3 presents the simulation model used to calculate the energy output of floating PV plants and the methods used to determine the optimum tilt angle of the panels and to evaluate the energy benefits provided. Section 4 presents the results and discussion of tilt angle optimization, the levelized cost of energy (LCOE) value, and the energy gains associated with the coordinated operation proposed in this paper. Finally, Section 5 presents the conclusions of the study.

2. Literature review

2.1. Floating PV projects

Trapani and Santafé [14] presented a timeline with several floating solar energy generation systems that were installed from 2007 to 2013 around the world considering facilities with fixed panels and tracking systems. The photovoltaic panels covered the surfaces of enclosed water bodies (reservoirs and lakes) mainly used for irrigation purposes. In floating PV plants constructed in Spain and Italy (at latitudes of approximately 40°), the tilt angle of the panels reached as high as 10°. The main benefits presented by these projects included increasing the electricity output by up to 25% in Bubano, Italy, as a result of the cooling effect from the water and reducing evaporation from the reservoir. In this context, Choi [11], who compared the energy production of a floating PV plant with that of a nearby plant constructed on land for 7 months, reported an ideal slope of 11°, which results in an average production gain of 7.6% for floating panels. Sacramento et al. [15] performed a comparative analysis of a module on the ground and another in a water tank with an inclination of 0° in a semi-arid region of Brazil. The results showed an average increase in efficiency of approximately 12.5% for the panel in the water tank. Ueda et al. [16] analyzed the production of a floating PV system compared to one installed on the margin of Aichi Lake in Japan over 5 years. They observed a reduction of 17% to 7.4% in the loss index due to the increase in temperature.

Sahu et al. [17] reviewed floating photovoltaic projects that were built prior to 2016 and added some new developments to a previously published project list [14]. Recently, two plants with capacities above 1 MWp were installed on the Nishihira and Higashihira ponds in Kato City, Korea. The floating systems that were used were manufactured with high-density polyethylene (HDPE). The same technology was used in the Research and Development (R & D) project subsidized by the San Francisco Hydroelectric Company (CHESF) in the Balbina and Sobradinho hydroelectric power plant reservoirs in Brazil. Each system had a potential output of 5 MWp. The energy generated by the floating PV systems complemented the produced hydroelectric energy. This approach takes advantage of two different energy sources using a single infrastructure that is already installed [18]. However, due to the recent construction of this project, the results have not yet been disclosed. Kim et al. [19] presented the PV floating projects developed in South Korea from 2009 to 2014. Between 2009 and 2010, the projects were for research purposes and, therefore, had small installed capacities. In 2011, some larger-scale PV floating projects were installed. The floating platforms of these projects had very similar designs, although the materials used in the construction of the structures varied and included steel fiber-reinforced polymer, polyethylene and plastic (FRP).

3. Materials and methods

3.1. Materials

The case study focused on the hydroelectric plants in the São Francisco River basin. These plants are located between the southeast and northeast regions of Brazil along the 2863 km that is occupied by the São Francisco River. Table 1 presents the main data from the hydroelectric plants that were analyzed.

The PV panel that was used in the simulation was a generic 250 W_p (60 cells) panel composed of polycrystalline silicon with dimensions of 1650 × 992 mm. This panel and the associated information is listed in the PVSyst® database [20].

The costs used in the calculation of the LCOE are presented in Table 2.

3.2. Computational simulation parameters

The PV energy calculation as a function of tilt angle, E_o (α), was performed in PVSyst®. In this software, there is no option to simulate a

Table 1
Main data for the hydroelectric plants that were analyzed.

Hydroelectric plant	Abbreviation	Installed capacity [MW]	Reservoir area [km^2]	Geographic coordinate [°]
Queimado	Queimado	105	39.43	−16.20, −47.32
Retiro Baixo	R. Baixo	82	22.58	−18.87, −44.77
Três Marias	T. Marias	396	1090	−18.21, −45.27
Sobradinho	Sobradinho	1050	4214	−9.43, −40.83
Itaparica	Itaparica	1480	828	−9.14, −38.31
Complex of Paulo Afonso and Apolônio Sales[a]	Comp. P. A and A. S	983.5	125.3	−9.42, −38.21
Xingó	Xingó	3162	60	−9.63, −37.79

[a] The set formed by the hydroelectric power plants of Paulo Afonso I, II, III and IV and Apolônio Sales is modeled as a single plant by the national system operator (ONS); therefore, the data provided are the generation set.

Table 2
Costs of a floating PV plant according to the tilt angle.

α [°]	PV equipment costs	Floating platform costs	Anchoring system costs	Total costs (R $/MW)
0	R$ 2,656,773.79	R$ 920,000.00	R$ 147,200.00	R$ 3,723,973.79
5	R$ 2,656,773.79	R$ 1,361,600.00	R$ 239,200.00	R$ 4,257,573.79
10	R$ 2,656,773.79	R$ 1,472,000.00	R$ 294,400.00	R$ 4,423,173.79
15	R$ 2,656,773.79	R$ 1,729,600.00	R$ 368,000.00	R$ 4,754,373.79
20	R$ 2,656,773.79	R$ 1,950,400.00	R$ 441,600.00	R$ 5,048,773.79
25	R$ 2,656,773.79	R$ 2,318,400.00	R$ 515,200.00	R$ 5,490,373.79
30	R$ 2,656,773.79	R$ 2,760,000.00	R$ 625,600.00	R$ 6,042,373.79

floating PV plant, but the available parameters and the simulation of the desired conditions can be adjusted, as shown in the following subsections. The simulations were performed for a 1 MW_p plant to obtain a normalized energy (MWh/MW_p). This approach allows the estimation of the generation for any peak power. A power density (kW_p/m^2) is also obtained, which can be used to estimate the area required for installation based on any peak power.

3.2.1. Simulation model used in PVSyst

The simulation model "Unlimited Sheds" was used to consider mutual shading losses among the rows of panels (Fig. 1). This effect can be significant for utility-scale PV plants if the inter-row distance (pitch) is not correctly sized. The number of hours per day for which mutual shading can be avoided is controlled through the "shading limit angle". In addition, increasing the pitch affects the ground occupancy factor, thereby requiring a larger installation area for the same PV peak power.

3.2.2. Albedo of water

Albedo is a measure of the potential that a surface has to reflect the radiation from the sun. A model for estimating the albedo (ρ) in different water bodies is presented in Eq. (1) [21]:

$$\rho = c^{r \cdot \sin\gamma + 1} \quad (1)$$

where c is the color coefficient, r is the roughness coefficient (due to undulations), and γ is the solar height.

Based on the coefficients presented in [21] for lakes and ponds with clear water and ripples of up to 2.5 cm ($c = 0.16$; $r = 0.70$), the albedo values for various sun heights can be obtained, as presented in Table 3.



Fig. 1. Parameters of the Unlimited Sheds model available in PVSyst.

Table 3
Albedo of the water as a function of solar height γ.

Sun height γ [°]	Albedo ρ
10	0.128
20	0.103
30	0.084
> 40	0.070

Table 3 presents the values of albedo with an average and standard deviation equal to 0.096 ± 0.025. Thus, the albedo used for the simulation in PVSyst® was the average value of $\rho = 0.096$. This value is well below the default value (for the ground) of $\rho = 0.020$.

3.2.3. Natural wind cooling

The literature review did not yield a method for determining the natural wind cooling effect on PV panels that are installed on floating platforms. As such, based on wind flow obstruction at the back of the modules caused by the shape of the floating platforms, as shown in Fig. 2, the thermal behavior of PV modules was defined in PVSyst® as "Integration with fully insulated back", i.e., without natural cooling at the back.

3.2.4. Increased-efficiency PV panels

The peak power (W_p) of the PV panel decreases by 0.5% per °C of cell temperature increase in the standard test conditions (STC) value on average [22]. For modules operating on the ground, [15] and [23] reported temperatures of 42.8 °C and 65.1 °C, respectively. With the objective of absorbing the heat surplus that is generated by the PV panel, Bahaidarah et al. [23] used a stream of water on the back of a PV panel and obtained a 34% reduction in temperature. Therefore, because the PV modules that are installed on floating platforms have natural water flows below their back surfaces, they operate at lower temperatures and with higher efficiencies than modules installed on land.

Therefore, an analysis of the results presented in [11,15,16] allows us to conclude that differences in climate and the tilt of PV modules are the most important variables that increase the efficiency of PV panels installed on floating platforms. Therefore, a conservative value of 7% was considered the efficiency improvement for PV panels at Brazilian hydroelectric power plants. This value is used to estimate the normalized power (E_{norm}) generated by the floating PV plants.

3.3. Evaluation of the influence of the tilt angle on the energy cost

For the same peak power, a higher PV panel tilt demands greater spacing between rows to avoid mutual shading. This issues increases area required for PV panels, which represents larger floating platforms. The larger floating platforms increase the costs of storage, transport, field construction time, and anchorage systems (presented in Table 2). In contrast, depending on the location, larger tilts can maximize the energy that is collected by PV panels. Therefore, it must be determined whether the energy benefit offsets the additional costs.

LCOE analysis can indicate the tilt at which energy will be generated at the lowest price. Darling et al. [24] presented a simplified LCOE equation for utility-scale PV plants. To evaluate the best tilt option (α) for a floating PV design, the influence of α on the variables that are presented in the original equation must be considered. Then, the minimum value of the LCOE (α) function must be obtained according to Eq. (2):

$$min \;\; LCOE(\alpha) = \frac{C_i(\alpha) + \sum_{n=1}^{N} \frac{AO\;(\alpha)}{(1+DR)^n} - \frac{RV\;(\alpha)}{(1+DR)^n}}{\sum_{n=1}^{N} \frac{E_o\;(\alpha) \times (1-SDR)^n}{(1+DR)^n}} \quad (2)$$

where C_i (α) is the initial cost as a function of α; AO (α) is the annual



Fig. 2. Shape of floating platforms (a) Isifloating® and (b) Hydrelio® increased-efficiency PV panels.

cost of operation as a function of α, considered 1% of the investment value per year; RV (α) is the residual value as a function of α, considered 10% of the investment value; E_o (α) is the energy produced in year zero as a function of α; SDR is the degradation rate of the PV system, considered 0.6% per year; N is the number of exploitation years, considered 25 years; and DR is the discount rate, considered 10%.

To calculate the energy produced (E_o), losses due to mutual shading should be considered. These losses can only be avoided if the rows are very far apart, thereby making the cost of the floating system unreasonable [25]. Therefore, it is necessary to establish a period of the day in which the plant will be free of mutual shadows and ensure that it is not exceeded in when calculating the energy generated at different tilts (α).

3.4. Tilt angle restrictions (dust and wind actions)

3.4.1. Minimal tilt to avoid soiling losses

The analysis of soiling losses on the surface of PV modules is an important stage in the determination of α due to its negative influence on the absorption of solar radiation [26].

However, no studies were found in the literature related to the accumulation of dust on PV panels installed on reservoirs in Brazil. The default value of 3% was adopted in PVSyst® software annual soiling losses. According to the PVSyst® manual, this value provides a good estimation for minimum inclination angles between 2° and 3° [27].

3.4.2. Maximum tilt for limiting wind loads

It is of utmost importance to evaluate the adverse effects of the tilt angle of PV panels and the intensity of forces caused by the wind on the floating platform and anchoring system. However, current standards related to wind forces on structures are not adequate and do not provide aerodynamic or pressure coefficients to evaluate the forces associated with PV installations. In practice, coefficients of the structures that are similar to those for PV panels on platforms have been adopted [28].

From the Brazilian standard for calculating wind loads, NBR 6123 [29], a methodology for calculating the resulting forces on various structural elements and characteristic wind speeds in Brazilian regions can be obtained. The elements closest to a floating PV structure are considered as “flat water insulated cover”, and the cover represents the PV module that is open at the sides and back, as in the model shown in [30]. Additionally, a “1-sided roof in rectangular plant buildings” is considered. In this case, the roof represents a PV module that is totally or partially closed according to the models of the manufacturers Ciel et Terre [31] and Isifloating [32]. The maximum load that the system can withstand provides the technical constraint for the maximum value of α.

3.5. Limitation of PV peak power for Hydro/PV coordinated operation

The poor electrical quality of PV energy, which is a consequence of the randomness and intermittency of the solar resource, makes the integration of utility-scale PV plants into power systems difficult because it imposes risks to the operative stability of the system and creates associated high investments in spinning reserves [33]. Moreover, in interconnected systems, when the local market does not consume all the power that is generated, it is transmitted to remote markets that can be thousands of miles away. Therefore, a stable power source is essential for avoiding substantial changes in power flow and voltage fluctuations. Therefore, for large-scale PV generation, it is extremely important to improve power quality [9].

Due to their operational flexibility, hydroelectric plants have considerable potential for offsetting PV instability in real time [9,33]. Thus, according to An et al. [9], the principles of hydro/PV coordinated operation can be stated as follows.

- In short-term scheduling, hydropower can compensate for the variability of PV energy through its rapidly adjustable power output, as depicted in Fig. 3.
- In mid- to long-term scheduling and to meet the peak demand, the excess energy that is generated by the PV plant can compensate for the energy deficiency of the hydroelectric plant.

Implementing these combined systems can improve the quality of PV energy, thereby allowing its transmission to distant load centers [9,33].

To ensure that hydropower is capable of compensating for the power deficiency created by a steep decline in PV output, in the most important PV generation scenario, it is necessary to establish restrictions on the size of the PV plant. Fang et al. [33] conservatively established the installed capacity of a hydroelectric plant as the maximum limit of PV peak power to be installed according to Eq. (3). Economic factors are also evaluated for optimum PV plant design in [33].

$$0 \le N_{in}^{PV} \le N_{in}^{H} \tag{3}$$

where N_{in}^{PV} is the floating PV peak power and N_{in}^{H} is the power capacity of the hydroelectric plant.

3.6. Modeling of PV energy as an equivalent inflow to the hybrid plant

Because the PV power generated to complement the hydroelectric power prevents a certain volume of water from being consumed and is stored in the reservoir for use during peak periods, the model presented in [34] can be used to convert PV energy into an equivalent inflow that reaches the reservoir during the analysis period. In [34], the equivalent



Fig. 3. PV compensation through hydropower: the elimination of (a) the randomness and (b) the intermittency is verified..
Source: [9]

inflow is obtained by pumping water from a lower reservoir into an upper reservoir through a process that uses energy from a PV plant that is built on the ground and near a reversible hydroelectric plant. This approach can be used in this study by considering the pumping stage ideal; that is, all PV energy is converted into an equivalent inflow. Eq. (4) presents this relationship:

$$V_{EQ(i)} = \frac{E_{elPV(i)}}{d \cdot g \cdot H_{TE(i)}} \quad (4)$$

where $V_{EQ(i)}$ is the equivalent flow corresponding to the PV power generated in period i, $E_{elPV(i)}$ is the total energy generated by the floating PV plant in period i, d is the density of water (1000 kg/m^3), g is the gravitational constant (9.81 m/s^2), and $H_{TE(i)}$ is the hydraulic head in period i (m). The period i could represent hours, days, weeks, etc.

3.7. PV internal lines connecting solar power to a hydroelectric substation

For floating PV plants with installed power on the order of hundreds of megawatts, it is necessary to divide the PV array into sub-PV arrays to make the transmission of large blocks of energy through an internal line technically possible. The costs of these networks in the LCOE must be considered because the PV array may have to be built away from the hydroelectric substation due to environmental and water use issues. Thus, based on the limitations of low-voltage energy transmission [35], Fig. 4 displays the basic scheme of internal lines used to quantify the effects of the line length (i.e., cost) on the LCOE.

4. Results and discussion

4.1. Simulation results

The simulation parameters defined in Section 3.1 were used in simulations executed with PVSyst® for a floating PV power plant in the Três Marias hydroelectric reservoir for different tilt angles (α), and the results are presented in Table 4.

The maximum shading limit angle (θ) that ensures the floating PV plant at Três Marias will not suffer losses caused by mutual shading in a period of 8–16 h is θ = 32°. The value of θ is controlled by the spacing between the rows of panels, which is called pitch (P). The value of P is based on the greater value between the distance that ensures there are no losses due to mutual shading (P_{sha}) and the minimum distance required for performing plant maintenance (P_{man}). Normally, for higher tilts, the value of P_{sha} is greater than P_{man} because, under these conditions, more space between rows is necessary to avoid mutual shading. However, as α decreases, the rows may be approximated because the shadows that are cast by the panels are small. Thus, P_{sha} approaches P_{man} as α decreases, which, in this geographical location, occurs at α = 15°. At this point, P_{sha} must be equal to P_{man}, even though P_{sha}



Fig. 4. Basic scheme of internal lines for a floating PV power plant in a hydroelectric reservoir.

Table 4
Summary of the simulations for different topologies in the hydroelectric Três Marias Power Plant.

α [°]	θ [°]	UF	P_{man} [m]	P_{sha} [m]	P [m]	A_{flo} [m^2]	D_{Pow} [kW_p/m^2]	E_{nor} [MWh year/MW_p]
0	0	0.66	1.49	–	1.49	9860.6	0.101414	1651.1
1	2	0.66	1.49	–	1.49	9860.6	0.101414	1659.6
2	3.9	0.66	1.49	–	1.49	9860.6	0.101414	1667.7
3	5.9	0.66	1.49	–	1.49	9860.6	0.101414	1675.2
4	7.8	0.66	1.49	–	1.49	9860.6	0.101414	1682.3
5	9.7	0.66	1.49	–	1.49	9860.6	0.101414	1688.7
10	19.2	0.67	1.47	–	1.47	9713.4	0.102950	1711.7
15	27.0	0.68	1.46	1.37	1.46	9570.6	0.104487	1719.9
20	31.8	0.67	1.43	1.48	1.48	9713.4	0.102950	1715.7
25	31.9	0.63	1.40	1.57	1.57	10330.2	0.096804	1704.5
30	32	0.60	1.36	1.65	1.65	10846.7	0.092194	1683.1

represents a smaller spacing between rows, because a minimum space of 0.50 m is required for maintenance. This distance should be added to the horizontal projection of the panel to obtain P_{man}.

The change in P influences the utilization factor (UF), which is given by the ratio of the total area of the PV modules to the total area occupied by the PV power plant; the latter also considers the spacing P between rows. Therefore, because the total area of the PV modules used in this study for 1 MW_p is always 6508 m^2, the area occupied by each MW_p of the floating PV plant (A_{flo}) can be determined. The power density is obtained by taking the inverse of A_{flo} and can be used to estimate the area occupied to achieve any PV peak power. The normalized energy (E_{norm}) is the result of simulating 1 MW_p of generation in PVSyst®. This value can be used to estimate the energy generated by any installed system with a given peak power at this location. The same procedure was performed for other hydropower plants, but the results are only demonstrated based on the LCOE and E_{norm}.

4.2. Optimizing the PV panel tilt angle

4.2.1. Evaluation of influence of the tilt angle on the LCOE

The energy results from the previous section are related to costs of the floating PV system for determining the LCOE (α), as shown in the graphic in Fig. 5.

Although the analyzed hydroelectric plants are in distinct geographic regions with latitudes ranging from 9° to 19° south, similar LCOE (α) behavior is observed, with a minimum value (below R$290/MWh) at α = 0° that increases as α becomes larger. From this perspective, α should be less than 5°. However, an analysis based only on energy maximization, as presented in [25], would lead to very different results and target values of α ≈ 15° as the best option. However, this would imply values above R$338/MWh. Thus, the importance of considering economic factors in the design of floating PV plants is clear because the energy gain obtained by increasing α may not justify the increase in the cost of the system. The LCOE graphic can also be used to identify the hydropower plants in the basin where the construction of a floating PV plant is more financially viable, such as the Três Marias, Retiro Baixo, and Queimado plants in this case. These plants can be selected to stimulate the development of the sector with later expansion to other plants throughout the country.

There is one gap among the LCOE curves that visibly separates them into two groups. This separation is due to the considerable geographic distance between these groups. Specifically, the São Francisco River basin creates different climatic zones. The plants that receive more solar radiation (Três Marias, Retiro Baixo, and Queimado) exhibit small LCOEs for any α. Reviewing the geographical data in Table 1, it is apparent that neighboring hydroelectric plants exhibit very similar LCOE values.

4.2.2. Tilt angle restrictions due to soiling losses

Restricting the minimum value of α is based on the accumulation of dirt, as presented in Section 3.4.1. Thus, Eq. (5) represents this restriction condition.

$$\alpha \geqslant 3^{\circ} \tag{5}$$

4.2.3. Tilt angle restrictions due to wind loads

The restriction to the maximum value of α is based on the maximum load the anchorage system can withstand and the resistance of the floating elements. In accordance with the methodology presented in Section 3.4.2, the most severe situation occurs when the incidence angle of the wind is +45°. In these conditions, the horizontal forces on each floating platform as a function of α are presented in Fig. 6 for PV panels with dimensions presented in Section 3.

The maximum limit for the horizontal force (100 kN) defined in [28] was based on the limitation of the anchoring system considering that it would be technically and economically infeasible to build ground



Fig. 5. Graphic of the LCOE as a function of α.



Fig. 6. Horizontal force caused by the wind load on a PV panel as a function of α.



Fig. 7. Horizontal force based on the width of the floating platform.

foundations that are capable of withstanding larger forces. In floating PV plants with many rows, there is a reduction in the horizontal forces caused by the wind-break effect that the windward rows exert on the adjacent leeward rows. The coefficient of reduction Fs = 0.75 used in [28] was also considered for the construction of Fig. 7.

Fig. 7 shows that the larger the value of α is, the shorter the distance at which the maximum force of 100 kN will be reached, i.e., a smaller number of PV panel rows. Thus, the maximum possible length is approximately 2400 m, which can only be reached for a tilt angle of up to 3°. Because the floating PV plants in this study have a peak power on the order of hundreds of MW_p, the initial minimum length of the floating platform will be approximately 1000 m. This length is only valid for tilt less than 8° (dotted green[1] line). Eq. (6) presents the initial condition for the maximum tilt restriction.

$$\alpha \leqslant 8^{\circ} \tag{6}$$

Limiting the maximum value of α to 8° is in accordance with the tilt angles of the panels used in designs developed and presented in Ref. [28], in which the maximum angle was 10°. Thus, it is evident that even at latitudes higher than those of the hydroelectric basin of the São Francisco River in Brazil (e.g., in Spain and Italy), the tilt angle should not exceed 10° to limit the effects of wind, although in these tilts the energy collected by the PV panels is not the maximum.

4.2.4. Determination of the optimum tilt angle

To determine the optimum α, one should simultaneously consider the conditions presented in the three previous subsections. Eqs. (5) and (6) establish the upper and lower technical limits for α that are summarized in Eq. (7).

$$3^{\circ} \leqslant \alpha \leqslant 8^{\circ} \tag{7}$$

An analysis of the LCOE (α) graphic (Fig. 5) indicates that floating PV plants yield the lowest cost at tilts less than 5°. Based on this finding, the optimum tilt angle is defined as α = 3°. This α value is much smaller than those (ranging from 8° to 11°) used in other projects discussed in the literature review, and this difference is related to the sizing method. Previous studies based their values on maximizing the energy collected by the PV array (obviously limited by wind load) but did not consider the influence of increasing the angle on the cost of the

[1] For interpretation of color in Figs. 7–9, the reader is referred to the web version of this article.

Table 5
Peak powers and occupied areas of floating PV plants.

Hydroelectric	Type	Power [MW_p]	PV area [km^2]	Reservoir area [km^2]	Surface occupation [%]
Queimado	Storage reservoir	105	1.04	39.43	2.63%
Retiro Baixo	Storage reservoir	82	0.81	22.58	3.58%
Três Marias	Storage reservoir	396	3.90	1090	0.36%
Sobradinho	Storage reservoir	1050	10.35	4214	0.25%
Itaparica	Storage reservoir	1479.6	14.59	828	1.76%
Paulo Afonso I, II, III	Run-of-the-river	1417	13.97	4.8	291.09%
Paulo Afonso IV	Run-of-the-river	2462	24.28	12.9	188.19%
Apolônio sales	Run-of-the-river	400	3.94	98	4.02%
Xingó	Run-of-the-river	3162	28.98	60	48.31%

floating PV system. In addition, such projects used floats with very different characteristics than those used in this study (Fig. 2).

4.3. Coordinated Hydro/PV operation

4.3.1. Determination of maximum power for coordinated Hydro/PV operation

As presented in Section 3.4, the PV peak power must be limited to the value of the installed capacity of the hydropower plant. The area occupied for peak power (using the power density) and the percentage of the surface area of the reservoir occupied by each hydroelectric power plant can be determined from the optimum tilt $\alpha = 3^{\circ}$, as shown in Table 5.

The analysis includes two types of hydropower facilities: those with storage reservoirs and run-of-the-river plants. In the case of storage reservoir facilities, the floating PV plant occupies a maximum reservoir surface area of 3.58%, which in principle does not compromise other activities (tourism, fish farming, etc.). However, in the case of run-of-the-river facilities, the percentage of the surface occupied can reach 48.31%, which can cause serious conflicts with other activities. In addition, in the case of the Paulo Afonso I, II, III and IV hydroelectric plants, the areas occupied by the floating PV plant would be much larger than the surface areas of the available lakes (surpassing 100% occupancy). This is a very unique case because the Paulo Afonso complex comprises 4 hydroelectric power plants (Paulo Afonso I, II, III and IV), which have 2 small impoundments and a very high installed power (3880 MW). Thus, since it is not possible to construct floating PV plants with peak power equal to the installed capacity of the respective hydroelectric dams in the available area on the surface of the Paulo Afonso I, II, III and IV reservoirs, as described in Section 3.4, these cases were excluded from the energy analysis. The floating PV plant of the Apolônio Sales hydroelectric plant was also excluded from the energy analysis due to the lack of generation data, even though the area of the reservoir occupied by the floating PV plant is acceptable. The best reservoir location for constructing a PV arrangement depends on several environmental, economic, and technical factors, for which detailed information and studies of the reservoirs and their margins are necessary. These factors that will not be addressed in this study.

4.3.2. Expected floating PV generation

In terms of the designed tilt angle and peak power of each PV plant, annual and monthly PV generation can be estimated using the normalized energy (E_{norm}) calculated for each PV plant in the corresponding time interval. The bars in Fig. 8 show the average energy generated by the hydroelectric plants over the past 3 years according to the data available in [36–38], as well as the annual PV energy obtained from the computational simulation. In addition, the points on the curves show the capacity factors (CFs) of the hydroelectric plants without the contribution of the PV floating source (yellow curve) and with the contribution of the PV floating source (blue curve).

Fig. 8 shows a significant increase in PV energy production, which represents 51.0% of the average energy generated by the Xingó hydroelectric plant and exceeds the average power generated at the Retiro Baixo hydropower plant (105.6%), in which the hydroelectric generation CF (16.7%) is worse than that of the PV plant installed at the same location. Três Marias and Sobradinho also exhibited low CFs (near 20%) in the past 3 years, in these cases, the PV generation would represent a greater than 85% increase in energy generated and a CF upgrade of approximately 15%. The average annual energy gain produced by the proposed coordinated operation for the hydroelectric plants in the São Francisco River basin would be approximately 76%, and the average CF increase for the hybrid plants would be approximately 17.3% in relation to that of the original hydroelectric power plant without the contribution of PV energy.

4.3.3. Equivalent inflow for a floating PV plant

According to Section 3.5, PV energy can be converted into an equivalent inflow that reaches the reservoir and can be added to the natural inflow of the river, resulting in a total water inflow available in the analyzed period. Thus, the existing Brazilian optimization models can be used to program the dispatch of the hybrid plant formed by the hydroelectric and floating PV plants operating in a coordinated and complementary manner. Fig. 9 shows the inflows: the natural inflow of the river (in blue) and the equivalent PV (in red) and total (in green) flows for each hydroelectric plant in the São Francisco River basin.

The increase in the equivalent inflow is very similar to the increase in PV energy presented in Fig. 8 and is more representative of hydroelectric plants with low CFs. In these cases, the equivalent inflow created by the PV energy exceeds the natural inflow during the dry period, which in the southeastern and northeastern regions of Brazil is between May and November. As shown in Eq. (4), the equivalent inflow can be obtained for any time interval *i*. Since dispatch scheduling is usually done per operative week, it is sufficient to obtain the normalized PV energy and hydraulic head available per week to calculate the weekly equivalent inflows.

Under the current regulatory perspective of the Brazilian electricity market, it is only appropriate to add the equivalent inflow from the PV source to the natural flow of the river if the prices of both power sources are the same. However, the sale price of hydroelectric energy registered at the last auction was R$ 166.92/MWh [39], which makes it impossible to consider the flow rates together. However, since the objective of this work is to perform an energy analysis for a future scenario in which it is estimated that the sale price of PV energy will be close to that of hydroelectric energy, regulatory issues are not addressed.

4.4. Impact of internal lines on the LCOE

To technically enable the transmission of the energy generated by low-voltage PV panels to the hydroelectric substation, it is necessary to increase the voltage to standardized high-voltage levels (13.8 kV, 34.5 kV, 69 kV, etc.) and to build internal lines aboveground or underground to transmit energy. The cost of these transmission systems is a linear function of the length of the internal lines; therefore, the greater the distance the floating PV plant is built from the hydroelectric



Fig. 8. Annual energy generated by the hydroelectric plants and floating PV plants.

substation, the greater the cost is. Fig. 10 presents the variation in the LCOE as a function of the length of the underground 13.8-kV collection network that transmit the energy from the 4.7 MVA subarray, as shown in Fig. 3. The internal lines could be configured with higher voltages or by constructing a substation for which the energy from all the subarrays would be input and few high-voltage lines (preferably compatible with the voltage level of the hydroelectric substation: 138 kV, 230 kV, etc.) would transmit the output. The criterion for choosing the best configuration is economic based and is not presented in this study.

5. Conclusions

Recent climate changes and intense drought have contributed to a decrease in hydroelectric production and an increase in the dependence on thermoelectric power plants to meet energy needs, especially in the northeast region of Brazil. In this sense, this study presents an alternative to complement the hydroelectric plants through coordinated operation with utility-scale PV floating plants. The addition of large PV plants to compensate for hydroelectric plants could reduce the variability and intermittency of the PV energy source and improve the energy quality, which is one of the greatest obstacles of large-scale applications in power systems. Additionally, the PV plant can complement the hydroelectric plant during drought periods (when clouds are less common). Furthermore, this approach increase the capacity of the hydroelectric plant to meet peak demands of the system because during daylight hours, the PV energy prevents a certain volume of water from being consumed, and this volume can be used for generation during the peak period.

For hydro/PV coordinated operation, the two plants must be connected to the electrical system through the same substation. Thus, the PV plant must be built close to the hydroelectric plant. Because of this issue, floating PV plants on the surface of the plant reservoir, rather than located in nearby areas that generally have unfavorable topography for the construction of PV plants, are ideal. Cost is another limiting factor for the use of PV sources; therefore, a technical and economic analysis of the various design variables of a floating PV system was presented. Among these variables, tilt has one of the greatest influences on the LCOE due to increases in the costs of the floating system that are directly proportional to the tilt angle. Thus, the choice of tilt based only on the technical criterion of energy maximization can lead to LCOE values that make this technology unfeasible. The distance from the floating PV plant to the hydroelectric substation is another factor to consider in the design stage because it can make the cost of energy unfeasible. LCOE costs for an internal line of up to 20 km (ranging from R$320/MWh to R$342/MWh) are competitive when compared to some thermal plants that have been dispatched in recent



Fig. 9. Natural, equivalent and total inflows for each hydroelectric plant in the São Francisco River basin.



Fig. 10. Variation of the LCOE as a function of the length of internal lines.

years in the Brazilian power system.

The results of the simulations in PVSyst® for floating PV plants suggest a significant increase in energy output, varying from 51.2% to 105.6%, for the hybrid power plants (formed by the hydroelectric and floating PV plants). To incorporate the energy results into the existing optimization algorithms of the electric system, a method is presented to model the PV energy as an equivalent inflow that can be added to the natural flow of the river to obtain the total inflow reaching the hybrid plant. An analysis of the monthly profiles of these flows revealed the ability of the floating PV plant to complement the hydropower plant in the dry period, in which the equivalent inflow exceeded the natural inflow of the river. This approach represents a valuable possibility to store more water for the hydroelectric plant and, consequently, to reduce the dependence on thermal complementation to meet power system demands.

Acknowledgements

The authors would like to thank the Brazilian National Council for Scientific and Technological Development (*Conselho Nacional de Desenvolvimento Científico e Tecnológico*, CNPq; in Portuguese) for granting a productivity in research scholarship to Prof. Regina Mambeli Barros (PQ2, Process number: 301986/2015-0) and Prof. Geraldo Lúcio Tiago Filho and to the Brazilian Coordination for the Improvement of Higher Education Personnel (*Coordenação de Aperfeiçoamento de Pessoal de Nível Superior*, Capes; in Portuguese) for granting the Master of Science scholarship to Naidion Motta Silvério and the Doctorate scholarship to Ivan Felipe da Silva dos Santos.

References

[1] Empresa de Pesquisas Energéticas. Balanço energético nacional 2016. 2016. [Online]. Available: https://ben.epe.gov.br/downloads/Relatorio_Final_BEN_2016.pdf. [Accessed: 22-Nov-2017].
[2] Freitas V, Olímipio A, Junior P, Hunt JD, Aur M. Enhanced-pumped-storage: combining pumped-storage in a yearly storage cycle with dams in cascade in Brazil. Energy 2014;78:513–23.
[3] Bruno R, et al. Maximizing hydro share in peak demand of power systems long-term operation planning. Electr Power Syst Res 2016;141:264–71.
[4] de Lucena AFP, et al. The vulnerability of renewable energy to climate change in Brazil. Energy Policy 2009;37(3):879–89.
[5] Prado FA, Athayde S, Mossa J, Bohlman S, Leite F, Oliver-Smith A. How much is enough? An integrated examination of energy security, economic growth and climate change related to hydropower expansion in Brazil. Renew Sustain Energy Rev 2016;53:1132–6.
[6] Silveira JL, Tuna CE, Lamas WDQ. The need of subsidy for the implementation of photovoltaic solar energy as supporting of decentralized electrical power generation in Brazil. Renew Sustain Energy Rev 2013;20:133–41.
[7] Energiewende A. Current and future cost of photovoltaics current and future cost of photovoltaics; 2015. [Online]. Available: https://www.ise.fraunhofer.de/content/dam/ise/de/documents/publications/studies/AgoraEnergiewende_Current_and_Future_Cost_of_PV_Feb2015_web.pdf. [Accessed: 23-Nov-2017].
[8] Omran WA, Kazerani M, Salama MMA. Investigation of methods for reduction of power fluctuations generated from large grid-connected photovoltaic systems. IEEE Trans Energy Convers 2011;26:318–27.
[9] An Y, et al. Theories and methodology of complementary hydro/photovoltaic operation: applications to short-term scheduling. J Renew Sustain Energy 2015;7. http://dx.doi.org/10.1063/1.4939056.
[10] Ramos DS, Schilling MT, Antonio J, Rosa DO. Expansão da capacidade do atendimento de ponta no Sistema Interligado Brasileiro. Revista USP 2015:103–21.
[11] Choi Y. A study on power generation analysis of floating PV system considering environmental impact. Int J Softw Eng Its Appl 2014;8(1):75–84.
[12] das Á. Ana AN. Cadernos de Recursos Hídricos O TURISMO E O LAZER E SUA INTERFACE. [Online]. Available: www.dominiopublico.gov.br/%0Adownload/texto/an000007. [Accessed: 14-Jul-2017].
[13] Andrade M, Cosenza P, Pinguelli L, Lacerda G. The vulnerability of hydroelectric generation in the Northeast of Brazil: the environmental and business risks for CHESF. Renew Sustain Energy Rev 2012;16:5760–9.
[14] Trapani K, Santafé MR. A review of floating photovoltaic installations: 2007–2013. Prog Photovolt Res Appl 2014;15(February 2003):659–76.
[15] do Sacramento EM, Carvalho PCM, de Araújo JC, Riffel DB, Corrêa RM da C, Neto JSP. Scenarios for use of floating photovoltaic plants in Brazilian reservoirs. IET Renew Power Gener 2015:1019–25.
[16] Ueda Y, Kurokawa K, Konagai M, Takahashi S, Terazawa A, Ayaki H. Five years demonstration results of floating pv systems with water spray cooling. In: 27th european photovoltaic solar energy conference and exhibition; 2012. no. March 2009. pp. 3926–3928.
[17] Sahu A, Yadav N, Sudhakar K. Floating photovoltaic power plant: a review. Renew Sustain Energy Rev 2016;66:815–24.
[18] MME. Ministério Brasileiro de Minas e Energia. Hidrelétrica Balbina inicia projeto com flutuadores para gerar energia solar; 2016. Available: http://www.mme.gov.br/web/guest/pagina-inicial/outras-noticas/-/asset_publisher/32hLrOzMKwWb/content/hidreletrica-balbina-inicia-projeto-com-flutuadores-para-gerar-energia-solar [accessed: 08-Apr-2017] (In Portuguese).
[19] Kim S-H, Yoon S-J, Choi W, Choi K-B. Application of floating photovoltaic energy generation systems in south Korea. Sustainability 2016;8(12):1333.
[20] Mermoud A. PVsyst Trial v6.63; 2017.
[21] Trapani K. Flexible floating thin film photovoltaic (PV) array concept for marine and lacustrine environments. Laurentian University; 2014.
[22] Messenger RA, Ventre J. Photovoltaic system engineering. 2nd ed. Taylor & Francis e-Library; 2004.
[23] Bahaidarah H, Subhan A, Gandhidasan P, Rehman S. Performance evaluation of a PV (photovoltaic) module by back surface water cooling for hot climatic conditions. Energy 2013;59:445–53.
[24] Darling SB, You F, Veselka T, Velosa A. Assumptions and the levelized cost of energy for photovoltaics. Energy Environ Sci 2011;4(9):3133–9.
[25] Santafé MR, Torregrosa-Soler JB, Romero FJS, Ferrer-Gisbert PS, Ferrán-Gozálvez JJ, Ferrer-Gisbert CM. Theoretical and experimental analysis of a floating photovoltaic cover for water irrigation reservoirs. Energy 2014;67:246–55.
[26] Xu R, Ni K, Hu Y, Si J, Wen H, Yu D. Analysis of the optimum tilt angle for a soiled

PV panel. Energy Convers Manag 2017;148:100–9.
[27] Mermoud Andre. In sheds arrangement, which power can I install on a given area ?; 2017. [Online]. Available: http://forum.pvsyst.com/viewtopic.php?f=20&t=1994&p=5389&hilit=Ground+Coverage+Ratio#p5389 [accessed: 26-Jul-2017].
[28] Santafé MR. Diseño de un sistema de cubierta flotante fotovoltaica para balsas de riego. Universidade Politécnica de Valencia; 2011.
[29] Associação Brasileira de Normas Técnicas. NBR 6123 - Forças devidas ao vento em edificações. Rio de Janeiro: ABNT; 1988. p. 66.
[30] Ferrer-Gisbert C, Ferrán-Gozálvez JJ, Santafé MR, Ferrer-Gisbert P, Sánchez-Romero FJ, Torregrosa-Soler JB. A new photovoltaic floating cover system for water reservoirs. Renew Energy 2013;60:63–70.
[31] et Terre C. Hydrelio® Components. [Online]. Available: http://www.ciel-et-terre.net/hydrelio-technology/ [accessed: 22-Oct-2017].
[32] Isigenere Renovables. Floating System for Photovoltaic Installations - Isifloating. p. 2.
[33] Fang W, Huang Q, Huang S, Yang J, Meng E, Li Y. Optimal sizing of utility-scale photovoltaic power generation complementarily operating with hydropower: a case study of the world's largest hydro-photovoltaic plant. Energy Convers Manag 2017;136:161–72.
[34] Glasnovic Z, Margeta K, Omerbegovic V. Artificial water inflow created by solar energy for continuous green energy production. Water Resour Manag 2013;27:2303–23.
[35] Hau Eric. Wind turbines. 2nd ed. Krailling: Springer; 2006.
[36] CCEE. Camara Brasileira de comercialização de energia. InfoMercado Individual 2014; 2015. [Online]. Available: https://www.ccee.org.br/portal/faces/acesso_rapido_header_publico_nao_logado/biblioteca_virtual?_afrLoop=234927870073880#%40%3F_afrLoop%3D234927870073880%26_adf.ctrl-state%3D8dejbt4mo_54 [accessed: 31-Mar-2017].
[37] CCEE. Camara Brasileira de comercialização de energia. InfoMercado Individual 2015; 2016. [Online]. Available: https://www.ccee.org.br/portal/faces/acesso_rapido_header_publico_nao_logado/biblioteca_virtual?_afrLoop=234927870073880#%40%3F_afrLoop%3D234927870073880%26_adf.ctrl-state%3D8dejbt4mo_54.
[38] CCEE. Camara Brasileira de comercialização de energia. InfoMercado Individual 2016; 2017. [Online]. Available: https://www.ccee.org.br/portal/faces/acesso_rapido_header_publico_nao_logado/biblioteca_virtual?_afrLoop=234927870073880#%40%3F_afrLoop%3D234927870073880%26_adf.ctrl-state%3D8dejbt4mo_54.
[39] de pesquisas energética EPE E. 23o LEILÃO DE ENERGIA NOVA A-5 Resumo Vendedor; 2016. [Online]. Available: http://www.epe.gov.br/sites-pt/publicacoes-dados-abertos/publicacoes/PublicacoesArquivos/publicacao-120/Resultado_completo_site_23_len.pdf. [Accessed: 29-Nov-2017].